



Ref. Certif. No.

SE-96335

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded case circuit-breakers (MCCB)
Name and address of the applicant	Zhejiang ETEK Electrical technology Co., Ltd. No. 288 Weil 17th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P. R. China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Shangtu Electrical technology Co., Ltd. NO.268 Wei 20th Road, Yueqing Economic Development Zone, Yueqing, Wenzhou, Zhejiang Province, P. R. China
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	EKM8T-160S, EKM8T-160H, EKM8T-250S, EKM8T-250H
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	190702336SHA-001, 190702336SHA-002

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 3 December 2019

intertek

Signature:


Henrik Wikström

Ratings and principal characteristics

Model:	EKM8T-160H, EKM8T-160S
Ue:	400V, 3P, 4P(3P+N)
Ratings Current (In):	25, 32, 40, 50, 63, 80, 100, 125, 160A; Ir= (0,7-1,0) In
Icu (kA):	35kA (EKM8T-160H), 25kA (EKM8T-160S)
Ics (kA):	25kA (EKM8T-160H), 18kA (EKM8T-160S)
Category:	Cat. A
Frequency:	50/60Hz
Other information:	Ui= 1000V~, Uimp=8kV, Ref. temperature: +40°C
Model:	EKM8T-250H, EKM8T-250S
Ue:	400V, 3P, 4P(3P+N)
Ratings Current (In):	125, 160, 200, 250A; Ir= (0,7-1,0) In
Icu(kA):	35kA (EKM8T-250H), 25kA (EKM8T-250S)
Ics(kA):	25kA (EKM8T-250H), 18kA (EKM8T-250S)
Category:	Cat. A
Frequency:	50/60Hz
Other information:	Ui= 1000V~, Uimp=8kV, Ref. temperature: +40°C

Date: 3 December 2019

Signature: 